

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Surge Protective Device

Name and address of the applicant

Wenzhou Britec Electric Co., Ltd.  
Block 1, BoTongHuiGu Industrial Park, Yueqing, 325600  
Zhejiang  
P.R. China

Name and address of the manufacturer

Wenzhou Britec Electric Co., Ltd.  
Block 1, BoTongHuiGu Industrial Park, Yueqing, 325600  
Zhejiang  
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Wenzhou Britec Electric  
Block 1, BoTongHuiGu Industrial Park, Yueqing, 325600  
Zhejiang  
P.R. China

Ratings and principal characteristics

Uc:1) and 3) 275V (L/N-PE); 2) and 4) 275V (L-N), 255V (N-PE)  
In:1) and 3) 25kA (L/N-PE); 2) and 4) 25kA (L-N), 50kA (N-PE)  
Iimp :1) and 3) 12.5kA (L/N-PE); 2) and 4) 12.5kA (L-N), 50kA (N-PE)  
Up:1) and 3) 1.3kV (L/N-PE); 2) and 4) 1.3kV (L-N), 1.5kV (N-PE)  
Iscrc:25kA; Class I+Class II; One port; Indoor

Trademark / Brand (if any)

BRITEC

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

1) BR-12.5M 275 aP, 2) BR-12.5M 275 bP+N  
3) BR-7M 275 aP, 4) BR-7M 275 bP+N  
(a=1, 2, 3, 4; b=1 or 3)

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

CN2360H5 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2023-10-11

Signature:



Wencai Zhang